

कार्यालय- उप जिला चिकित्सालय, प्रेमनगर, देहरादून।

Email Id- chpremnagar@gmail.com दूरभाष संख्या- 0135-2770006

पत्रांक: प्रेमनगर/विविध-110/2026-27/ 38

दिनांक: 20 अप्रैल, 2026

प्रेषित,

Principal  
Jim Pioneer School  
Pitamberpur, Premnagar  
Dehradun

विषय: जिम्प पायनियर स्कूल, पीताम्बरपुर, आरकेडिया ग्राण्ट, देहरादून को स्वास्थ्य एवं स्वच्छता प्रमाण पत्र 2026-27 सत्र के लिये निर्गत किये जाने के संबंध में।

उपरोक्त विषयक आपके पत्र दिनांक: 10.04.2026 का संदर्भ ग्रहणकरने की कृपा करे, जिसके द्वारा आपके द्वारा संचालित किये जा रहे जिम्प पायनियर स्कूल, पीताम्बरपुर, आरकेडिया ग्राण्ट, देहरादून को स्वास्थ्य एवं स्वच्छता प्रमाण पत्र 2026-27 निर्गत किये जाने हेतु प्रार्थना पत्र अधोहस्ताक्षरी को प्रस्तुत किया गया है,, जिसे फलस्वरूप मेरे द्वारा आपके स्कूल का दिनांक: 13.04.2026 को निरीक्षण किया गया था, तदोरान्त निरीक्षण के दौरान स्कूल में पानी साफ एवं सफाई व्यवस्था अच्छी पायी गयी।

अतः आपके द्वारा चाहा गया प्रमाण पत्र, मूल रूप में पत्र के साथ संलग्न कर सूचनार्थ एवं आवश्यक कार्यवाही हेतु आपको प्रेषित। किया जा रहा है।

संलग्न-यथोपरि।



मुख्य चिकित्सा अधीक्षक  
उप जिला चिकित्सालय  
Chief Medical Superintendent  
Government Sub District Hospital  
प्रेमनगर, देहरादून।  
Premnagar, Dehradun

  
PRINCIPAL  
JIMP PIONEER SCHOOL  
Pitamberpur, Premnagar  
Dehradun (Uttarakhand)

  
MANAGER  
Jimp Pioneer School  
Pitamberpur, Arkedia Gram  
Dehra Dun, Uttarakhand

कार्यालय- उप जिला चिकित्सालय, प्रेमनगर, देहरादून।

Email Id- chpremnagar@gmail.com दूरभाष संख्या- 0135-2770006

पत्रांक: प्रेमनगर/विविध-110/2026-27/  
2026

दिनांक: 20 अप्रैल,

-:प्रमाण-पत्र:-

This is to certify that Jimp Pioneer School, situated at Pitamberpur, Arcadia Grant Premnagar Dehradun has good hygienic and safe drinking water facilities and proper sanitation arrangements for all students and teachers on the school campus.



मुख्य चिकित्सा अधीक्षक  
उप जिला चिकित्सालय  
प्रेमनगर, देहरादून।  
Chief Medical Superintendent  
Government Sub-District Hospital  
Premnagar, Dehradun



**PRINCIPAL**  
JIMP PIONEER SCHOOL  
Pitamberpur, Premnagar  
Dehradun (Uttarakhand)



**MANAGER,**  
Jimp Pioneer School  
Pitamberpur, Arcadia Grant  
Dehra Dun, Uttarakhand

**SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE**

No.

Dated:

It is certified that an inspection team headed by Dr. Parmarth Joshi, CMS

(Name of Officers with designation) from SDH, Premnagar, ddn PHED

inspected the JIMP PIONEER SCHOOL, PITAMBERPUR, Arcadia Grant, ddn

(Name & Address of the school) on 13/04/2026 (date of inspection) and on the basis of Water Test


Report (Attached) bearing no. 1325/LTS/DLWQTML/2025-26 dated 27/02/2026

of District Level Water Quality (PHED Lab) Testing & Monitoring Laboratory certified that the Jimp Pioneer school

(Name of school) has safe drinking water facilities for the students and members of staff of the institution.

School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till .....

Signature with Seal: 

Name : Dr. PARMARTH JOSHI

Designation : C.M.S, SDH, Premnagar

Name & Address if the Office/ Department: Chief Medical Superintendent

Government Sub District Hospital, ddn  
Premnagar, Dehradun

To JIMP PIONEER SCHOOL

Pitamberpur, Arcadia Grant, Premnagar, ddn

(Name & Address of the Institution)

Note: The Certificate is to be issued by authorized officer / PHED Lab/ local bodies



**PRINCIPAL**  
**JIMP PIONEER SCHOOL**  
**Pitamberpur, Premnagar**  
**Dehradun (Uttarakhand)**



**MANAGER**  
**Jimp Pioneer School**  
**Pitamberpur, Arcadia Grant**  
**Dehra Dun, Uttranchal**



**District Level Water Quality Testing and Monitoring Laboratory  
Uttarakhand Jal Sansthan, 32, Rajpur Road, Dehradun**



TC-13625

**TEST REPORT**

Name and Address of Organization/ Customer	<b>Jimp Pioneer School, Add-Pitamberpur, Arcadia Grant, Dehradun, Uttarakhand.</b>		
Test Report ID	1325/UJS/DLWQTML/2025-26	Reporting Date	05/03/2026
Date and Time of Sample Received:	27/02/26 & 02:00 PM	Sample Location	Add-Pitamberpur, Arcadia Grant, Dehradun, Uttarakhand
Product Description	Drinking Water	Sample Collected by	Customer
Reference Sample Identification:	DLWQTML/UJS/2026-1325	Duration of Analysis	27/02/2026 to 02/03/2026

SN	Parameters	Test Method	Result	Requirement (Acceptable Limit) As per (IS 10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
<b>(A) Organoleptic and Physical Parameters</b>					
1.	pH at 25°C	IS 3025 (Part 11)	7.25	6.5 to 8.5	No Relaxation
2.	Total Dissolved Solids (TDS), at 180°C mg/L	IS 3025 (Part 16)	220	500 Max	2000 Max
3.	Turbidity, NTU	IS 3025 (Part 10)	0.68	1 Max	5 Max
4.	Colour, CU	IS 3025 (Part 4)	Less than 01	5 Max	15 Max
5.	Odour	IS 3025 (Part 5)	Agreeable	Agreeable	Agreeable
<b>(B) General Parameters Concerning Substances</b>					
6.	Total Alkalinity (as CaCO <sub>3</sub> ), mg/L	IS 3025 (Part 23)	112	200 Max	600 Max
7.	Total Hardness (as CaCO <sub>3</sub> ), mg/L	IS 3025 (Part 21)	174	200 Max	600 Max
8.	Calcium as Ca, mg/l	IS 3025 (Part 40)	31.2	75 Max	200 Max
9.	Chloride as Cl, mg/L	IS 3025 (Part 32)	21	250 Max	1000 Max
10.	Magnesium as Mg, mg/l	APHA 24 <sup>th</sup> Ed-3500-Mg Method B: 2023 (Calculation Method)	23.32	30 Max	100 Max
<b>(C) Microbiological Parameters</b>					
	Parameters	Test method	Results	Requirements as per IS 10500:2012	
11.	Total Coliform (in 100ml)	IS 15185:2016	Absent	Shall not be detectable in any 100 ml sample	
12.	E. coli, (in 100ml)	IS 15185:2016	Absent	Shall not be detectable in any 100 ml sample	

Note -

1. The results listed refer only to tested sample and applicable parameters 2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory. 3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer. 4. The results apply to the sample as received 5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

\*\*\*\* End of Report\*\*\*\*

Review and Authorized By

(Dr. Vikash Khandari)  
Technical Manager

Technical Manager  
DLWQTML  
Uttarakhand Jal Sansthan  
Dehradun

Principal  
**JIMP PIONEER SCHOOL**  
Pitamberpur, Premnagar  
Dehradun (Uttarakhand)

**MANAGER,**  
Jimp Pioneer School  
Pitamberpur, Arcadia Grant  
Dehra Dun, Uttaranchal



**District Level Water Quality Testing and Monitoring Laboratory  
Uttarakhand Jal Sansthan, 32, Rajpur Road, Dehradun**

**TEST REPORT**

Name and Address of Organization/ Customer	<b>Jimp Pioneer School. Add-Pitamberpur, Arcadia Grant, Dehradun, Uttarakhand.</b>		
Test Report ID	1325A/UJS/DLWQTML/2025-26	Reporting Date	05/03/2026
Date and Time of Sample Received:	27/02/26 & 02:00 PM	Sample Location	Add-Pitamberpur, Arcadia Grant, Dehradun, Uttarakhand
Product Description	Drinking Water	Sample Collected by	Customer
Reference Sample Identification:	DLWQTML/UJS/2026-1325	Duration of Analysis	27/02/2026 to 02/03/2026

SN	Parameters	Test Method	Results	Requirement (Acceptable Limit) As per (IS 10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
<b>(D) General Parameters Concerning Substances</b>					
1.	Fluoride, mg/L	IS 3025 (Part60/Sec 1)	Less than 0.2	1.0 Max	1.5 Max
2.	Nitrate, mg/L	IS 3025 (Part34/Sec 1)	Less than 01	45 Max	No Relaxation
3.	Sulfate, mg/L	IS 3025 (Part24/Sec 1)	20	200 Max	400 Max

**Note -**

1. The results listed refer only to tested sample and applicable parameters. 2. This certificate is not to be reproduced wholly or in parts for promotional publicity or legal purpose without permission of authority of testing laboratory. 3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer. 4. The results apply to the sample as received. 5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer.

\*\*\*\* End of Report\*\*\*\*

Review and Authorized By

(Dr. Vikash Kandari)  
Technical Manager, Lab

Technical Manager  
DLWQTML  
Uttarakhand Jal Sansthan  
Dehradun

**PRINCIPAL  
JIMP PIONEER SCHOOL  
Pitamberpur, Arcadia Grant,  
Dehradun (Uttarakhand)**

**MANAGER,**

**Jimp Pioneer School  
Pitamberpur, Arcadia Grant  
Dehradun, Uttarakhand**